

MA检测报告

152512050049 TEST REPORT

报告编号 YNZKBG20230509011
 Report No

项目名称 华新水泥（昭通）有限公司 2023年第二季度比对监测
 Name

委托单位 华新水泥（昭通）有限公司
 Client

项目地址 昭通市昭阳区北山镇塘房村
 Address

样品类别 空气和废气
 Type

编制: 杨怀艳
 Compiled by

校核: 杨怀艳
 Proofread/Check

审核: 杨怀艳
 Inspected by

签发: 杨怀艳
 Approved by

签发日期: 2023年05月29日
 Approved Date Y M D

云南中科检测技术有限公司
 Yunnan Kinno-sci Testing Technol. Co, LTD

报告日期: 2023年05月29日
 Report Date Y M D



声 明 Introduction

单位“检测专用章”及“骑缝章”无效。

Unit CMA qualification certification seal and special seal for

名无效，报告经涂改无效。

name, audit staff signature, approver signature is invalid,

全文复制除外) 本报告或证书。

(except in full) without the approval of the agency .

检测报告对样品所检项目的符合性情况负责，送样样
除委托方特别声明并支付样品管理费以外，所有样品
不再留样。

tested, the test report shall be responsible for the
sample, and the client shall be responsible for the
sample submitted; Unless the entrusting party makes a
management fee, the timeliness of all samples exceeding
technical specifications will not be retained.

完整性、真实性、准确性负责。本公司实施的所有检
测提供的信息为前提，当委托方提供的信息可能影响结
果的任何责任。

responsibility for the completeness, authenticity and accuracy of the
testing behaviors and related reports provided by our
company provided by the entrusting party. When the information
provided by the entrusting party may affect the effectiveness of the results, our company will not
be responsible for them.

广告，商品宣传等商业行为。

The testing organization shall not be used for advertising,
promotional practices.

如有异议，请于收到报告之日起十五日内向本公司提出申请，
逾期不予受理。

If you have any objections, please apply to the company within 15 days from
the date of receipt of the report. If the client fails to apply within the time limit, it shall be
irrevocable.

地址：昆明经开区云大西路 39 号新兴产业孵化区 3 幢 3 层厂房
Address: 3 Building, Emerging Industry Incubation Zone,
Kunming Economic and Technological Development
Zone.

样品基本情况											
样品类别	样品名称	采样点位		采样频次		采样人员	采样时间	收样人员	收样时间	分析时间	样品状态描述
		A1: 窑磨废气袋除尘 (DA019)	A2: 熟料电收尘器 (DA004)	天数	次/天						
空气和废气	有组织 排放废气	1	1	6/9	甘果 邹泽辉 吕海 李正友	2023.05.16	杨婷	2023.05.17	2023.05.17- 2023.05.19	—	

150586137

联系电话

工号

联系人

		氮氧化物	回走与资源废气 氮氧化物的测定 定电位电解法				mg/m ³
--	--	------	---------------------------	--	--	--	-------------------

实测浓度	烟气参数							排气筒	件号编号	采样日期	采样点位	检测项目
	检测结果	标干流量 (m³/h)	含氧量 (%)	含湿量 (%)	静压 (kPa)	烟温 (°C)	流速 (m/s)					
7.1	223148	6.6	8.74	-0.02	116.2	17.8	17.8	YNZKSC20230412003-A001				A1: 窑磨废
10.5	228087	6.4	7.95	-0.02	119.7	18.2	18.2	YNZKSC20230412003-A002				A1: 窑磨废
8.9	233096	6.8	8.21	-0.02	122.3	18.8	18.8	YNZKSC20230412003-A003				A1: 窑磨废
9.2	231364	6.9	8.11	-0.03	121.4	18.6	18.6	YNZKSC20230412003-A004	90			布袋除尘 (DA019)
8.6	231717	7.2	8.07	-0.02	118.4	18.5	18.5	YNZKSC20230412003-A005				(DA019)
7.7	227407	7.5	7.25	-0.02	118.5	18.0	18.0	YNZKSC20230412003-A006				
8.7	229137	6.9	8.06	-0.02	119.4	18.3	18.3	平均值		2023.05.16		
5.8	147878	—	—	—	—	—	—	YNZKSC20230412003-A010				
4.5	180704	—	3.20	-0.01	76.9	12.2	12.2	YNZKSC20230412003-A012	30			A2: 熟料电
3.8	148723	—	2.72	-0.01	70.2	9.8	9.8	YNZKSC20230412003-A013				收尘器 (DA004)
5.1	150585	—	3.15	-0.01	88.1	10.5	10.5	YNZKSC20230412003-A014				
6.2	145330	—	3.12	-0.01	90.4	10.1	10.1	YNZKSC20230412003-A015				
4.8	160652	—	3.25	-0.01	92.3	11.0	11.0	平均值				

表 3 有组织排放废气检测结果表

NO.1

3. 检测结果

ReportNo
报告编号: YNZKKBG20230529011



氮氧化物

YNZKSC20230412003-A006	18.0	118.5	-0.02	7.25	7.5	227407	284
YNZKSC20230412003-A007	17.8	121.4	-0.02	7.35	7.8	222700	221
YNZKSC20230412003-A008	18.0	120.4	-0.02	7.74	7.3	224824	262
YNZKSC20230412003-A009	18.3	122.1	-0.02	7.10	7.2	229166	273
平均值	18.2	120.0	-0.02	7.8	7.1	227945	272

报告结束



华新水泥（昭通）有限公司 2023 年第二季度对比监测点位置图

ReportNo
报告编号: YNZKKBG20230529011
附图:

